Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK127

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WOLF,LACEY			Phone #
Mailing Address: 1747 133RD AVE			
City: ST CROIX FALLS	State: WI	Zip Code: 54024	
County: Polk	Co. Permit #:	Notification #: 10048615601	Completed: 11-06-2025

1. Well Location

Town of BALSAM LAKE

Fire # (if avail.)

Street Address or Road Name and Number: 1747 133RD AVE

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
COX, BRYAN	6644	

Latitude / Longitude in Decimal Degree (DD): 45.3994 °N -92.5186 °W

Method Code: SCR002

Address: BLC WELL DRLG & PUMP SERV 1649 210TH AVE MILLTOWN WI 54858

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

SW	SE	Section	Township	Range
or Govt Lot #		30	34 N	17 W

2. Well Type Replacement

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.3

Reason for replaced or reconstructed well ?

SANDPOINT

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	45
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	45	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND 6.625X.280 18.99LB PER FT WELDED STEEL	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 18 SLOT	55	58

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC	6644	12-04-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25

Comment:

Created On: 11-12-2025 Updated On: 10-15-2026 Review Status: APPROVED