

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK211		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner JIM DEGRAVES						Phone # (920)609-3851		1. Well Location				Fire # (if avail.)		
Mailing Address N10015 NEWTON LAKE RD						Town of STEPHENSON						N10021		
City CRIVITZ						State WI		Zip Code 54114				Street Address or Road Name and Number NEWTON LAKE RD		
County Marinette		Co. Permit #		Notification # 10039515901		Completed 11-07-2025		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) COOPER, GERALD L				Lic. # 6211		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.325 °N -88.1231 °W				Method Code SCR002		
Address 5050 BROWN RD LITTLE SUAMICO WI 54141				Well Plan Approval #		NE NE		Section 21		Township 33 N		Range 19 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		2. Well Type New Well								
3. Well serves 1 # of NEW HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8		Surface		3		No Rotary - Mud Circulation				No				
6		3		48		No Rotary - Air				No				
						No Rotary - Air & Foam				No				
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						Yes Cable-tool Bit 8in. dia...				No				
						No Dual Rotary				No				
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
T S S				T-TAN/BROWN S-SOFT/LOOSE S-SAND				Surface		48				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 36 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
6		STEEL, 18.97 LB PER FT ASTM A53 NTP-TRI WELDED				Surface		45						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		SLOTTED STAINLESS STEEL 10 SLOT				45		48						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface		45		1 S						
9. Static Water Level														
16 ft. below ground surface														
10. Pump Test														
Pumping level 37 ft. below surface														
Pumping at 15 GP M for 2 Hrs.														
Pumping Method ? Test Pump														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller				Lic #		Date Signed								
GLC				6211		11-14-2025								
Drill Rig Operator				Lic or Reg #		Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 11-14-2025

Updated On: 12-22-2025

Review Status: APPROVED