Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK244

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCCABE, CHRISTIAN			Phone #
Mailing Address: 220 STOKELY RD N			
City: MILLTOWN	State: WI	Zip Code: 54858	
County: Polk	Co. Permit #:	Notification #: 10058415201	Completed: 11-20-2025

Well Constructor (Business Name): BEECROFT, BRANT C	Lic. #: 7298	Facility ID # (Public Wells):	
Address: DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Village of MILLTOWN

Fire # (if avail.)

Street Address or Road Name and Number
STOKELY RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.5386 °N -92.4994 °W	SCR002

NE	NW	Section	Township	Range
or Govt Lot #		8	35 N	17 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	482

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	8
		Y	Z	Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	8	12
		Z		Z-CLAY & GRAVEL	12	18
		Y		Y-SAND & GRAVEL	18	25
		K		K-COBBLES/BOULDERS	25	30
		Y		Y-SAND & GRAVEL	30	40
		C	Z	C-CLAY Z-W/COBBLES/BOULDERS	40	50
		C	G	C-CLAY G-W/GRAVEL/STONES	50	57
	W	P	Z	W-WATER BEARING P-HARDPAN Z-W/COBBLES/BOULDERS	57	71
	N	X		N-FINE X-SAND & CLAY	71	80
		C		C-CLAY	80	91
	H	B		H-HARD/FIRM B-BASALT OR TRAP ROCK	91	482

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM A53B PLN END BT WLD	Surface	92.2
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	92.2	1 S

9. Static Water Level

45 ft. below ground surface

10. Pump Test

Pumping level 460 ft. below surface

Pumping at 7.5 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BCB	7298	12-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		80

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	11/28/2025	.25

Created On: 11-17-2025 Updated On: 01-27-2026 Review Status: APPROVED