Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACK245

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HURLEY, KEITH	Phone #: (651)248-6085
Mailing Address: 1795 70TH ST E	
City: INVER GROVE HEIGHTS	State: MN — Zip Code: 55077
County: Burnett	Co. Permit #:
Notification #: 10057718601	Completed: 11-15-2025
Well Constructor (Business Name): BEECROFT, BRANT C	Lic. #: 7298
Facility ID # (Public Wells):	
Address: DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Town of LA FOLLETTE	Fire # (if avail.): 4396
Street Address or Road Name and Number: SPENCER LAKE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.741 °N -92.2053 °W	Method Code: SCR002

SW	SE	Section	Township	Range
or Govt Lot #		27	38 N	15 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: WELL IN PIT/LOW YEILD

Construction Type: Drilled

3. Well serves 2 # of HOME, SHED

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50.2

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	X-SAND & CLAY	Surface	28
Z	Z-CLAY & GRAVEL	28	43
Y	Y-SAND & GRAVEL	43	50.2

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM A53B PLN END BT WLD	Surface	46.1
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON SS #12	46.1	50.2

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	46.1	1 S

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

SANDPOINT WILL BE ABANDONED IN 2026 WHEN IT IS REMOVED FROM SERVICE.

13. Constructor / Supervisory Driller	Lic #	Date Signed
BCB	7298	12-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	POWTS dispersal component (soil absorption unit or mound)		70

Comment:

Created On: 11-17-2025 Updated On: 10-15-2026 Review Status: APPROVED