

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK245		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner HURLEY, KEITH				Phone # (651)248-6085		1. Well Location				Fire # (if avail.)	
Mailing Address 1795 70TH ST E						Town of LA FOLLETTE				4396	
City INVER GROVE HEIGHTS				State MN Zip Code 55077		Street Address or Road Name and Number SPENCER LAKE RD					
County Burnett		Co. Permit #		Notification # 10057718601		Completed 11-15-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) BEECROFT, BRANT C				Lic. # 7298		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.741 °N -92.2053 °W		Method Code SCR002	
Address DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 27 38 N 15 W		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? WELL IN PIT/LOW YEILD			
3. Well serves 2 # of HOME, SHED Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock								
6 Surface 50.2			No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)					
X			X-SAND & CLAY			Surface			28		
Z			Z-CLAY & GRAVEL			28			43		
Y			Y-SAND & GRAVEL			43			50.2		
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)					
6		WHEATLAND ASTM A53B PLN END BT WLD				Surface		46.1			
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)					
5		JOHNSON SS #12				46.1		50.2			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement							
GRANULAR BENTONITE				Surface 46.1		1 S					
9. Static Water Level											
16 ft. below ground surface											
10. Pump Test											
Pumping level 20 ft. below surface											
Pumping at 10 GP M for 1 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
24 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? No											
SANDPOINT WILL BE ABANDONED IN 2026 WHEN IT IS REMOVED FROM SERVICE.											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
BCB				7298		12-30-2025					
Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	POWTS dispersal component (soil absorption unit or mound)		70

Comment:

Created On: 11-17-2025

Updated On: 01-27-2026

Review Status: APPROVED