Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK339

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	CORY SCHRADER
Phone #	
Mailing Address	N5838 PIONEER ROAD
City	FREDONIA
State	WI
Zip Code	53021
County	Ozaukee
Co. Permit #	
Notification #	10057326501
Completed	11-17-2025
Well Constructor (Business Name)	GROTH WATER WELLS INC
Lic. #	639
Facility ID # (Public Wells)	
Address	W69 N949 WASHINGTON AVE CEDARBURG WI 53012
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.6

1. Well Location

Town of FREDONIA

Fire # (if avail.)

Street Address or Road Name and Number: N5838 PIONEER ROAD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.48855 °N -87.99957 °W	GPS008

NW SW or Govt Lot #	Section	Township	Range
	21	12 N	21 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	205

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	D	G-GRAVEL/STONES D-W/GLACIAL MATERIAL	Surface	45
T		S		T-TAN/BROWN S-SAND	45	49
		Z	S	Z-CLAY & GRAVEL S-SANDY	49	52
	B	L	D	B-BROKEN L-LIMESTONE/DOLOMITE D-W/GLACIAL MATERIAL	52	59
I		L		I-WHITE L-LIMESTONE/DOLOMITE	59	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# ASTM A53 P.E. NUCOR	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface		3 S

9. Static Water Level

42 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
FB	67	11-17-2025
Drill Rig Operator	Lic or Reg #	Date Signed
SMB	8729	11-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	100
POWTS dispersal component (soil absorption unit or mound)	>	200

Type	Qualifier	Distance
Building Drain - Sanitary		30
Sewer - Building Sanitary		35

Comment:

Created On: 11-18-2025 Updated On: 01-23-2026 Review Status: APPROVED