

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK377		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PRICE SAM						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address N 4623 PIEPER RD						Town of STUBBS						N4623									
City WEYERHAEUSER						State WI		Zip Code 54895				Street Address or Road Name and Number PIEPER RD									
County Rusk		Co. Permit #		Notification # 10056407602		Completed 11-18-2025		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) KRAMER WELL DRILLING LLC				Lic. # 8118		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.4549 °N -91.4101 °W				Method Code GPS008							
Address PO BOX 71 WEYERHAEUSER WI 54895				Well Plan Approval #		NE SW		Section 6		Township 34 N		Range 8 W									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well											
Hicap Well ? No				Hicap Property ? No				Reason for replaced or reconstructed well ?													
Private, potable				Hicap Potable ? No				Construction Type Drilled													
Heat Exchange ___ # of drillholes																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		130		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						T Q Z		T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL		Surface		123			
												T A Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL		123		130			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		99 ft. below ground surface				26 in. above grade							
6		P.E. STEEL 19#/F T ASTM A53				Surface		127		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 101 ft. below surface				Disinfected ? Yes							
3		S.S. WIRE WOUND #20				127		130		Pumping at 12 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				No			
Method		MOUNDED												Filled & Sealed Well(s) as needed?				No			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
GRANULAR BENTONITE		Surface				3 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed					
AFH														7393		11-19-2025					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		82	POWTS dispersal component (soil absorption unit or mound)		92
			Building Drain - Sanitary		63

Comment:

Created On: 11-19-2025

Updated On: 12-29-2025

Review Status: APPROVED