Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK377

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PRICE SAM			Phone #
Mailing Address: N 4623 PIEPER RD			
City: WEYERHAEUSER	State: WI	Zip Code: 54895	
County: Rusk	Co. Permit #:	Notification #: 10056407602	Completed: 11-18-2025

1. Well Location

Town of STUBBS	Fire # (if avail.): N4623
Street Address or Road Name and Number: PIEPER RD	
Subdivision Name	Lot # / Block #

Well Constructor (Business Name): KRAMER WELL DRILLING LLC	Lic. #: 8118	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 45.4549 °N -91.4101 °W	Method Code: GPS008
Address: PO BOX 71 WEYERHAEUSER WI 54895		Well Plan Approval #	NE SW / or Govt Lot #:	Section: 6 / Township: 34 N / Range: 8 W
		Approval Date (mm-dd-yyyy)		
Hicap Permanent Well #	Common Well #	Specific Capacity: 6		

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	130

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Z		T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL	Surface	123
T	A	Y		T-TAN/BROWN A-COARSE Y-SAND & GRAVEL	123	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL 19#/F T ASTM A53	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	S.S. WIRE WOUND #20	127	130

9. Static Water Level
99 ft. below ground surface

10. Pump Test
Pumping level 101 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AFH	7393	11-19-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		82	POWTS dispersal component (soil absorption unit or mound)		92
			Building Drain - Sanitary		63

Comment:

Created On: 11-19-2025 Updated On: 10-15-2026 Review Status: APPROVED