Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK378

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NORTHWOODS DOCK AND LIFT	Phone #
Mailing Address: 699 E HWY 48	
City: BIRCHWOOD	State: WI / Zip Code: 54817
County: Sawyer	Co. Permit #:
Notification #: 10057141701	Completed: 11-14-2025
Well Constructor (Business Name): KRAMER WELL DRILLING LLC	Lic. #: 8118
Facility ID # (Public Wells): 858025520	
Well Plan Approval #:	
Address: PO BOX 71 WEYERHAEUSER WI 54895	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 18	

1. Well Location

Town of EDGEWATER	Fire # (if avail.): 16878 W
Street Address or Road Name and Number: HWY 48	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.6628 °N -91.5396 °W	Method Code: GPS008
SW NW or Govt Lot #:	Section: 30 / Township: 37 N / Range: 9 W

2. Well Type Replacement

of previous unique well #: VC105 constructed in: 2009

Reason for replaced or reconstructed well ?: LOW VOLUME

Construction Type: Drilled

3. Well serves 1 # of SHOP

Non-community

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q Z	T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL	Surface	11
T A K	T-TAN/BROWN A-COARSE K-COBBLES/BOULDERS	11	51
G Q Y	G-GRAY Q-CAVING Y-SAND & GRAVEL	51	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL 19#/F T ASTM A53	Surface	76
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S.S. WIRE WOUND #20	76	79

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		4 S

9. Static Water Level

53 ft. below ground surface

10. Pump Test

Pumping level 54 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

PUMP INSTALLER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
AFH	7393	11-19-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		65	POWTS dispersal component (soil absorption unit or mound)		90
			Building Drain - Sanitary		50

Comment:

Created On: 11-19-2025 Updated On: 07-29-2026 Review Status: APPROVED