

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK378		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner NORTHWOODS DOCK AND LIFT						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 699 E HWY 48						Town of EDGEWATER						16878 W					
City BIRCHWOOD						State WI		Zip Code 54817				Street Address or Road Name and Number HWY 48					
County Sawyer		Co. Permit #		Notification # 10057141701		Completed 11-14-2025		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) KRAMER WELL DRILLING LLC				Lic. # 8118		Facility ID # (Public Wells) 858025520		Latitude / Longitude in Decimal Degree (DD) 45.6628 °N -91.5396 °W				Method Code GPS008					
Address PO BOX 71 WEYERHAEUSER WI 54895				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 30 37 N 9 W		2. Well Type Replacement of previous unique well # VC105 constructed in 2009 Reason for replaced or reconstructed well ? LOW VOLUME Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 18													
3. Well serves 1 # of SHOP Non-community Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		79		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				T Q Z T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL T A K T-TAN/BROWN A-COARSE K-COBBLER/BOULDERS G Q Y G-GRAY Q-CAVING Y-SAND & GRAVEL		Surface 11 51 51 79					
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 53 ft. below ground surface				11. Well Is 24 in. above grade			
6		P.E. STEEL 19#/F T ASTM A53				Surface		76		10. Pump Test Pumping level 54 ft. below surface Pumping at 18 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		S.S. WIRE WOUND #20				76		79									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? Yes					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No PUMP INSTALLER WILL							
GRANULAR BENTONITE				Surface				4 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
AFH												7393		11-19-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		65	POWTS dispersal component (soil absorption unit or mound)		90
			Building Drain - Sanitary		50

Comment:

Created On: 11-19-2025

Updated On: 07-29-2026

Review Status: APPROVED