Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK405

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAND AND CABIN			Phone #
Mailing Address: 40335 GOVERMENT RD			
City: HINCKLEYHINCKLEY	State: MN	Zip Code: 55037	
County: Burnett	Co. Permit #:	Notification #: 10062372101	Completed: 11-19-2025

1. Well Location

Town of JACKSON

Fire # (if avail.)

Street Address or Road Name and Number: DEERPATH TERRACE

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KENT, ROBERT W	6791	

Address: KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.9706 °N -92.204 °W	SCR002

NW NE or Govt Lot #	Section	Township	Range
	10	40 N	15 W

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.3

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	89

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WEATLAND SCH 40 .280 18.97	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON STAINLESS STEEL 10 SLOT	81	89

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 25 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	81	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK	6791	12-17-2025
Drill Rig Operator	Lic or Reg #	Date Signed
RK		12-17-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-19-2025 Updated On: 01-23-2026 Review Status: APPROVED