

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK405		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner LAND AND CABIN Phone #						1. Well Location				Fire # (if avail.)	
Mailing Address 40335 GOVERMENT RD						Town of JACKSON					
City HINCKLEYHINCKLEY State MN Zip Code 55037						Street Address or Road Name and Number DEERPATH TERRACE					
County Burnett		Co. Permit #		Notification # 10062372101		Completed 11-19-2025		Subdivision Name		Lot #	Block #
Well Constructor (Business Name) KENT, ROBERT W				Lic. # 6791	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9706 °N -92.204 °W		Method Code SCR002		
Address KENT WELL DRILLING 749 SEBOE RD WRENSHALL MN 55797				Well Plan Approval #		NW NE Section 10 Township 40 N Range 15 W or Govt Lot #	2. Well Type New Well				
				Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
6 Surface 89						S		S-SAND		Surface 89	
		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ____ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ____ in. dia <u>No</u> Removed? ____ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen						9. Static Water Level			11. Well Is		
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		50 ft. below ground surface			20 in. above grade				
6 WEATLAND SCH 40 .280 18.97		Surface 81		10. Pump Test			Developed ? Yes				
Dia. (in.) Screen type, material & slot size		From (ft.) To (ft.)		Pumping level 70 ft. below surface			Disinfected ? Yes				
4 JOHNSON STAINLESS STEEL 10 SLOT		81 89		Pumping at 25 GP M for 1 Hrs.			Capped ? Yes				
7. Grout or Other Sealing Material						Pumping Method ? Airlift					
Method MOUNDED						12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement		Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE		Surface 81									
						13. Constructor / Supervisory Driller		Lic #		Date Signed	
						RK		6791		12-17-2025	
						Drill Rig Operator		Lic or Reg #		Date Signed	
						RK				12-17-2025	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-19-2025

Updated On: 01-23-2026

Review Status: APPROVED