Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK419

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOE HATHAWAY			Phone #
Mailing Address: 157 147TH ST			
City: DEER PARK	State: WI	Zip Code: 54007	
County: Polk	Co. Permit #:	Notification #: 10060477201	Completed: 11-17-2025

Well Constructor (Business Name): COX, BRYAN	Lic. #: 6644	Facility ID # (Public Wells):	
Address: BLC WELL DRLG & PUMP SERV 1649 210TH AVE MILLTOWN WI 54858		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.9	

1. Well Location

Town of ALDEN

Fire # (if avail.):

Street Address or Road Name and Number: 157 147TH ST

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.2323 °N -92.4656 °W

Method Code: SCR002

SW	NW	Section	Township	Range
or Govt Lot #		27	32 N	17 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	78

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		Z		R-RED Z-CLAY & GRAVEL	Surface	35
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	35	55
I	N	S		I-WHITE N-FINE S-SAND	55	65
I		L		I-WHITE L-LIMESTONE/DOLOMITE	65	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND 6.625X.280 18.99LB PER FT WELDED STEEL	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC	6644	12-12-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment: NEW HOUSE. WATER TEST WILL BE LATE.

Created On: 11-20-2025 Updated On: 10-15-2026 Review Status: APPROVED