Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK500

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FORD, RYAN	Phone #
Mailing Address: S37W34784 CTY RD D	
City: DOUSMAN	State: WI — Zip Code: 54175
County: Oconto	Co. Permit #: — Notification #: 10086676401 — Completed: 01-30-2026
Well Constructor (Business Name): T & T WELL DRILLING & PUMP SERVICE	Lic. #: 6571 — Facility ID # (Public Wells):
Address: PO BOX 22 LAKEWOOD WI 54138	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of TOWNSEND	Fire # (if avail.): 17393
Street Address or Road Name and Number: MC CASLIN DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.3116 °N -88.6138 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 27 — Township: 33 N — Range: 15 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	10
6	10	63

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	G	X-SAND & CLAY G-W/GRAVEL/STONES	Surface	10
		Y		Y-SAND & GRAVEL	10	25
		S		S-SAND	25	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A-53 GRADE B WHEATLAND WELDED 18.97	Surface	59
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	10# SLOT SS	59	63

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	10	4 S

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM	6220	02-11-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB	8359	02-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-23-2025 Updated On: 10-15-2026 Review Status: APPROVED