Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK500

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	FORD, RYAN
Phone #	
Mailing Address	S37W34784 CTY RD D
City	DOUSMAN
State	WI
Zip Code	54175
County	Oconto
Co. Permit #	
Notification #	10086676401
Completed	01-30-2026
Well Constructor (Business Name)	T & T WELL DRILLING & PUMP SERVICE
Lic. #	6571
Facility ID # (Public Wells)	
Well Plan Approval #	
Address	PO BOX 22 LAKEWOOD WI 54138
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0

1. Well Location

Town of TOWNSEND	Fire # (if avail.) 17393
Street Address or Road Name and Number	MC CASLIN DR
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	45.3116 °N -88.6138 °W
Method Code	SCR002
NW SW or Govt Lot #	
Section	27
Township	33 N
Range	15 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of CABIN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	10
6	10	63

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	G	X-SAND & CLAY G-W/GRAVEL/STONES	Surface	10
		Y		Y-SAND & GRAVEL	10	25
		S		S-SAND	25	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A-53 GRADE B WHEATLAND WELDED 18.97	Surface	59

Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	10# SLOT SS	59	63

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	10	4 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 30 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM	6220	02-11-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB	8359	02-11-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-23-2025 Updated On: 03-02-2026 Review Status: APPROVED