

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK539		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner LORI NIMMER					Phone #		1. Well Location Fire # (if avail.) 1492					
Mailing Address 1492 LAKE SHORE RD					Town of GRAFTON							
City GRAFTON			State WI		Zip Code 53024		Street Address or Road Name and Number 1492 LAKE SHORE RD					
County Ozaukee		Co. Permit #		Notification # 10066482301		Completed 11-24-2025		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) LIEBAU, ARTHUR JAMES				Lic. # 23		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.33212 °N -87.88965 °W			Method Code GPS008	
Address 1200 W LIEBAU RD MEQUON WI 53092				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 16 10 N 22 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6								
3. Well serves 1 # of OUTSIDE WATERING Private, potable Irrigation Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
6		Surface		265		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				C C-CLAY Surface 178 L L-LIMESTONE/DOLOMITE 178 265		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 80 ft. below ground surface		
6		STEEL 18.65LBS ASTM A53 NEWCORE PIPE WELDED				Surface		178		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 130 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ? Airlift		
7. Grout or Other Sealing Material Method MOUNDED												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No				
GRANULAR BENTONITE		Surface		178		4 S		Filled & Sealed Well(s) as needed? No				
13. Constructor / Supervisory Driller AJL Drill Rig Operator								Lic # 23 Lic or Reg #		Date Signed 11-24-2025 Date Signed		

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-24-2025

Updated On: 01-04-2026

Review Status: APPROVED