

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK575		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RUVIN BROTHERS						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 7095 N RIVER RD						Village of RIVER HILLS						7095							
City RIVER HILLS						State WI		Zip Code 53217				Street Address or Road Name and Number RIVER RD							
County Milwaukee		Co. Permit #		Notification # 10086714801		Completed 11-25-2025		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LIEBAU, ARTHUR JAMES				Lic. # 23		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.14595 °N -87.92644 °W				Method Code GPS008					
Address 1200 W LIEBAU RD MEQUON WI 53092				Well Plan Approval #		NE NE		Section 19		Township 8 N		Range 22 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of HOME				Hicap Well ? No															
Private, potable Borehole				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		125		No Rotary - Mud Circulation		No		C		C-CLAY		Surface		22			
						No Rotary - Air		Yes		Z		Z-CLAY & GRAVEL		22		70			
						No Rotary - Air & Foam		No		L		L-LIMESTONE/DOLOMITE		70		79			
						Yes Drill-Through Casing Hammer				L K		L-LIMESTONE/DOLOMITE K-W/BROKEN ROCK		79		85			
						No Reverse Rotary				L		L-LIMESTONE/DOLOMITE		85		117			
						No Cable-tool Bit ___ in. dia...		No		H		H-SHALE		117		125			
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				14 in. above grade					
6		STEEL 18.65LBS ASTM A53 NEWCORE PIPE WELDED PE				Surface		70		10. Pump Test				Developed ? Yes					
										Pumping level 70 ft. below surface				Disinfected ? Yes					
										Pumping at 50 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed?				No			
GRANULAR BENTONITE				Surface		70		2 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												AJL				23		11-25-2025	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		50

Comment:

Created On: 11-25-2025

Updated On: 01-04-2026

Review Status: APPROVED