

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK636		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LARSON, MOLLY						Phone # (218)730-7828		1. Well Location				Fire # (if avail.)					
Mailing Address 315 WILLIS AVE						Town of CLOVER						86020					
City ASHLAND						State WI		Zip Code 54806				Street Address or Road Name and Number					
County Bayfield						Co. Permit #		Notification # 10041065501		Completed 11-14-2025		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) MELIN, ROBERT T						Lic. # 111		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.8189 °N -91.2884 °W				Method Code GPS008			
Address MELIN WELL DRILLING 1318 MACARTHUR AVE ASHLAND WI 54806-3825						Well Plan Approval #		SW SE		Section 7		Township 50 N		Range 7 W			
								or Govt Lot #		7		50 N		7 W			
Hicap Permanent Well #						Common Well #		Specific Capacity 2.5		2. Well Type New Well				of previous unique well #		constructed in	
Heat Exchange ___ # of drillholes						Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No		Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME						Private, potable		Drillhole		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
10		Surface		161		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)									
		I		I-SOIL-ORGANIC		Surface		2									
		C		C-CLAY		2		60									
		X		X-SAND & CLAY		60		110									
A		S		A-COARSE S-SAND		110		115									
N		S		N-FINE S-SAND		115		125									
		S		S-SAND		125		140									
A		S		A-COARSE S-SAND		140		161									
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)									
5		PVC-SDR-17 250PSI F-450 EAGLE				Surface		141									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		JOHNSON-PVC-20 SLOT				141		161									
7. Grout or Other Sealing Material																	
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE		Surface		125		62 S											
9. Static Water Level																	
130 ft. below ground surface																	
10. Pump Test																	
Pumping level 132 ft. below surface																	
Pumping at 5 GP M for 2 Hrs.																	
Pumping Method ? Other																	
11. Well Is																	
12 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ? No																	
Filled & Sealed Well(s) as needed? No																	
13. Constructor / Supervisory Driller																	
Lic #		Date Signed															
RTM		111		12-01-2025													
Drill Rig Operator		Lic or Reg #		Date Signed													
JJJ		9257		12-01-2025													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-01-2025

Updated On: 02-04-2026

Review Status: APPROVED