Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK636

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LARSON, MOLLY	Phone #: (218)730-7828
Mailing Address: 315 WILLIS AVE	
City: ASHLAND	State: WI — Zip Code: 54806
County: Bayfield	Co. Permit #:
Notification #: 10041065501	Completed: 11-14-2025
Well Constructor (Business Name): MELIN, ROBERT T	Lic. #: 111
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MELIN WELL DRILLING 1318 MACARTHUR AVE ASHLAND WI 54806-3825	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Town of CLOVER	Fire # (if avail.): 86020
Street Address or Road Name and Number: 86020 BUCKLEY RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.8189 °N -91.2884 °W	Method Code: GPS008

SW	SE	Section	Township	Range
or Govt Lot #		7	50 N	7 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	161

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	2
		C		C-CLAY	2	60
		X		X-SAND & CLAY	60	110
	A	S		A-COARSE S-SAND	110	115
	N	S		N-FINE S-SAND	115	125
		S		S-SAND	125	140
	A	S		A-COARSE S-SAND	140	161

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC-SDR-17 250PSI F-450 EAGLE	Surface	141
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	JOHNSON-PVC-20 SLOT	141	161

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	125	62 S

9. Static Water Level

130 ft. below ground surface

10. Pump Test

Pumping level 132 ft. below surface

Pumping at 5 GP M for 2 Hrs.

Pumping Method ? Other

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RTM	111	12-01-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JJP	9257	12-01-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 12-01-2025 Updated On: 02-04-2026 Review Status: APPROVED