Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK668

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RASMUSSON, PAUL	Phone #
Mailing Address: 1695 W WHITE ASH DRIVE	
City: BALSAM LAKE	State: WI — Zip Code: 54810
County: Polk	Co. Permit #:
Notification #: 10056434901	Completed: 11-13-2025
Well Constructor (Business Name): COX, BRYAN	Lic. #: 6644
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: BLC WELL DRLG & PUMP SERV 1649 210TH AVE MILLTOWN WI 54858	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Town of APPLE RIVER

Fire # (if avail.):

Street Address or Road Name and Number: 1073 NIEBEL LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.4689 °N -92.3812 °W	SCR002

SE SW or Govt Lot #	Section	Township	Range
	32	35 N	16 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	97

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	25
T		C		T-TAN/BROWN C-CLAY	25	45
O		Y		O-ORANGE Y-SAND & GRAVEL	45	65
I	S	N		I-WHITE S-SOFT/LOOSE N-SANDSTONE	65	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND 6.625X.280 18.99LB PER FT WELDED STEEL	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 10 SLOT	94	97

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC	6644	12-12-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 12-02-2025 Updated On: 10-15-2026 Review Status: APPROVED