

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK715		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner BURTAUX, LAUREN					Phone # (952)737-7418			1. Well Location				Fire # (if avail.)				
Mailing Address PO BOX 159					Town of LA POINTE							1136				
City LAPOINTE					State WI		Zip Code 54850					Street Address or Road Name and Number 1136 SUNNY SLOPE RD				
County Ashland		Co. Permit #		Notification # 10019405501			Completed 11-10-2025			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) MELIN, ROBERT T					Lic. # 111		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 46.78639 °N -90.78211 °W			Method Code GPS008			
Address MELIN WELL DRILLING 1318 MACARTHUR AVE ASHLAND WI 54806-3825					Well Plan Approval #			NE NE		Section 30		Township 50 N		Range 3 W		
Approval Date (mm-dd-yyyy)					or Govt Lot #			2. Well Type New Well								
Hicap Permanent Well #					Common Well #		Specific Capacity 90			of previous unique well #					constructed in	
3. Well serves 1 # of HOME					Hicap Well ? No			Reason for replaced or reconstructed well ?								
Private, potable Drillhole					Hicap Property ? No			Construction Type Drilled								
Heat Exchange ___ # of drillholes					Hicap Potable ? No			Reason for replaced or reconstructed well ?								
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
10		Surface		69		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>						
6		69		140		<u>No</u> Rotary - Air				<u>No</u>						
						<u>No</u> Rotary - Air & Foam				<u>Yes</u>						
						<u>No</u> Drill-Through Casing Hammer										
						<u>No</u> Reverse Rotary										
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>						
						<u>No</u> Dual Rotary				<u>No</u>						
						<u>No</u> Temp. Outer Casing ___ in. dia										
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
C				C-CLAY				Surface		15						
Y				Y-SAND & GRAVEL				15		26						
X				X-SAND & CLAY				26		32						
S N				S-SOFT/LOOSE N-SANDSTONE				32		46						
H N				H-HARD/FIRM N-SANDSTONE				46		140						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		STEEL-20 LBS-FT-ASTM-A-53 B -WHEATLAND-T & C				Surface		70								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material																
Method TREMIE PIPE - PUMPED																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
NEAT CEMENT GROUT				Surface		69		26 S								
9. Static Water Level																
53 ft. below ground surface																
10. Pump Test																
Pumping level 57 ft. below surface																
Pumping at 6 GP H for 2 Hrs.																
Pumping Method ? Other																
11. Well Is																
15 in. above grade																
Developed ? Yes																
Disinfected ? Yes																
Capped ? Yes																
12. Notified Owner of need to fill & seal ? No																
Filled & Sealed Well(s) as needed? No																
13. Constructor / Supervisory Driller																
Lic #				Date Signed												
RTM				111 12-04-2025												
Drill Rig Operator				Lic or Reg #				Date Signed								
JLO				8457 12-04-2025												

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-04-2025

Updated On: 01-12-2026

Review Status: APPROVED