Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK715

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BURTAUX, LAUREN			Phone #: (952)737-7418
Mailing Address: PO BOX 159			
City: LAPOINTE	State: WI	Zip Code: 54850	
County: Ashland	Co. Permit #:	Notification #: 10019405501	Completed: 11-10-2025

1. Well Location
Town of LA POINTE
Fire # (if avail.): 1136
Street Address or Road Name and Number: 1136 SUNNY SLOPE RD
Subdivision Name | Lot # | Block #

Well Constructor (Business Name): MELIN, ROBERT T	Lic. #: 111	Facility ID # (Public Wells)	
Address: MELIN WELL DRILLING 1318 MACARTHUR AVE ASHLAND WI 54806-3825		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0	

Latitude / Longitude in Decimal Degree (DD): 46.78639 °N -90.78211 °W
Method Code: GPS008

NE	NE	Section	Township	Range
or Govt Lot #		30	50 N	3 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	69
6	69	140

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	C			C-CLAY	Surface	15
	Y			Y-SAND & GRAVEL	15	26
	X			X-SAND & CLAY	26	32
S	N			S-SOFT/LOOSE N-SANDSTONE	32	46
H	N			H-HARD/FIRM N-SANDSTONE	46	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL-20 LBS-FT-ASTM-A-53 B -WHEATLAND-T & C	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 57 ft. below surface
Pumping at 6 GP H for 2 Hrs.
Pumping Method ? Other

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	69	26 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RTM	111	12-04-2025
Drill Rig Operator	Lic or Reg #	Date Signed
JLO	8457	12-04-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 12-04-2025 Updated On: 10-15-2026 Review Status: APPROVED