

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK803		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CORDES, STEVE & DAWN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 60715 MAPLE RIDGE RD						Town of KELLY													
City MASON						State WI		Zip Code 54856											
County Bayfield		Co. Permit #		Notification # 9972890801		Completed 11-08-2025		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) KOSTAC, CHRISTOPHER L				Lic. # 7166		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.45221 °N -90.97774 °W				Method Code GPS008					
Address KOSTAC WELL DRILLING AND REPAIR 60358 JOHN JOHNSON RD ASHLAND WI 54806				Well Plan Approval #				SE NW		Section 22		Township 46 N		Range 5 W					
				Approval Date (mm-dd-yyyy)				or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement				of previous unique well # constructed in									
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				OLD WELL IN A PIT, WITH LIMITED ACCESS									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		235		No Rotary - Mud Circulation				No		X		X-SAND & CLAY		Surface		220	
						No Rotary - Air				No		W S		W-WATER BEARING S-SAND		220		235	
						No Rotary - Air & Foam				No									
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		215 ft. below ground surface				16 in. above grade					
6		STEEL ASTM 53 PLAIN END				Surface		231		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 230 ft. below surface				Disinfected ? Yes					
6		15 SLOT STAINLESS SCREEN (MALE X PLATE) WITH 6 X 5 K-PACKER				231		235		Pumping at 9 GP M for 24 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes					
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
GRANULAR BENTONITE				Surface		231													
13. Constructor / Supervisory Driller						Lic #		Date Signed											
CLK						7166		12-09-2025											
Drill Rig Operator						Lic or Reg #		Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: PRIMARILY SAND, WITH ALTERNATING, THIN CLAY STREAKS

Created On: 12-09-2025

Updated On: 12-26-2025

Review Status: APPROVED