Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK803

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	CORDES, STEVE & DAWN
Phone #	
Mailing Address	60715 MAPLE RIDGE RD
City	MASON
State	WI
Zip Code	54856
County	Bayfield
Co. Permit #	
Notification #	9972890801
Completed	11-08-2025
Well Constructor (Business Name)	KOSTAC, CHRISTOPHER L
Lic. #	7166
Facility ID # (Public Wells)	
Well Plan Approval #	
Address	KOSTAC WELL DRILLING AND REPAIR 60358 JOHN JOHNSON RD ASHLAND WI 54806
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.6

1. Well Location

Town of KELLY

Fire # (if avail.)

Street Address or Road Name and Number: 60715 MAPLE RIDGE RD

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 46.45221 °N -90.97774 °W

Method Code: GPS008

SE NW or Govt Lot # | Section: 22 | Township: 46 N | Range: 5 W

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?

OLD WELL IN A PIT, WITH LIMITED ACCESS

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	235

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X		X-SAND & CLAY	Surface	220
	W	S		W-WATER BEARING S-SAND	220	235

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM 53 PLAIN END	Surface	231
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	15 SLOT STAINLESS SCREEN (MALE X PLATE) WITH 6 X 5 K-PACKER	231	235

9. Static Water Level

215 ft. below ground surface

10. Pump Test

Pumping level 230 ft. below surface

Pumping at 9 GP M for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	231	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CLK	7166	12-09-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: PRIMARILY SAND, WITH ALTERNATING, THIN CLAY STREAKS

Created On: 12-09-2025 Updated On: 10-15-2026 Review Status: APPROVED