Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK864

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STARJENSKI, JOSH			Phone #
Mailing Address: 617 145TH AVE			
City: TURTLE LAKE	State: WI	Zip Code: 54889	
County: Polk	Co. Permit #:	Notification #: 10057161501	Completed: 11-14-2025

1. Well Location
Town of APPLE RIVER

Fire # (if avail.)

Street Address or Road Name and Number
617 145TH AVE

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
COX, BRYAN	6644	

Latitude / Longitude in Decimal Degree (DD): 45.4198 °N -92.2894 °W
Method Code: SCR002

SE NE or Govt Lot #	Section	Township	Range
	24	34 N	16 W

Address: BLC WELL DRLG & PUMP SERV 1649 210TH AVE MILLTOWN WI 54858

Well Plan Approval #

Approval Date (mm-dd-yyyy)

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.3

3. Well serves # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	138

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	Surface	73
R		Z		R-RED Z-CLAY & GRAVEL	73	90
R		M		R-RED M-SILT	90	125
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	125	138

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND 6.625X.280 18.99LB PER FT WELDED STEEL	Surface	135
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 18 SLOT	135	138

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BC	6644	12-12-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment: WATER TEST WILL BE LATE. NEW HOUSE

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	01/21/2026	

Created On: 12-12-2025 Updated On: 10-15-2026 Review Status: APPROVED