Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK874

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HUNTINGTON, SHANE	Phone #
Mailing Address: N6126 WOLF RIVER RD	
City: SHAWANO	State: WI — Zip Code: 54166

County	Co. Permit #	Notification #	Completed
Shawano		10105295801	02-27-2026

Well Constructor (Business Name): SHAWANO WELL DRILLING INC	Lic #: 6001
Address: W9618 ANGLE RD, SHAWANO WI 54166	

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7	

3. Well serves 1 # of BARNDO
Private,potable — Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? Yes

1. Well Location
Town of RICHMOND

Fire # (if avail.): N5624

Street Address or Road Name and Number: WOLF RIVER RD, SHAWANO, WI 54166

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)		Method Code
44.7933 °N	-88.6263 °W	GPS008

NW NW or Govt Lot #	Section	Township	Range
	25	27 N	15 E

2. Well Type New Well
of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	131

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY	Surface	17
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY	17	26
R	V	C	C	R-RED V-NON-CAVING C-CLAY C-CLAYEY	26	124
T	E	S	S	T-TAN/BROWN E-CLEAN S-SAND S-SANDY	124	131

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC CRESTLINE SDR17 ASTM D2241 SOLVENT WELD	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	WIRE WRAP 20 SLOT	127	131

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT HIGH SOLIDS	Surface	118	12 S
#40 GRAVEL PACK RED FLINT	118	131	7 S

9. Static Water Level
1 ft. above ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 50 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDD	6331	03-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JL	7417	03-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		20

Comment:

Created On: 12-15-2025 Updated On: 04-13-2026 Review Status: APPROVED