

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK874				Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HUNTINGTON, SHANE						Phone #						1. Well Location Fire # (if avail.) N5624					
Mailing Address N6126 WOLF RIVER RD						Town of RICHMOND											
City SHAWANO						State WI		Zip Code 54166						Street Address or Road Name and Number WOLF RIVER RD, SHAWANO, WI 54166			
County Shawano		Co. Permit #		Notification # 10105295801		Completed 02-27-2026		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) SHAWANO WELL DRILLING INC				Lic. # 6001		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7933 °N -88.6263 °W				Method Code GPS008			
Address W9618 ANGLE RD SHAWANO WI 54166				Well Plan Approval #				NW		NW		Section 25		Township 27 N		Range 15 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of BARND0				Private, potable Drillhole		Hicap Well ? No											
Heat Exchange ___ # of drillholes						Hicap Property ? No											
						Hicap Potable ? Yes											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
8.75		Surface		131		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
R	H	C	C	R-RED H-HARD/FIRM C-CLAY C-CLAYEY				Surface		17							
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY				17		26							
R	V	C	C	R-RED V-NON-CAVING C-CLAY C-CLAYEY				26		124							
T	E	S	S	T-TAN/BROWN E-CLEAN S-SAND S-SANDY				124		131							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
5		PVC CRESTLINE SDR17 ASTM D2241 SOLVENT WELD				Surface		127									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		WIRE WRAP 20 SLOT				127		131									
7. Grout or Other Sealing Material																	
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE GROUT HIGH SOLIDS				Surface		118		12 S									
#40 GRAVEL PACK RED FLINT				118		131		7 S									
9. Static Water Level																	
1 ft. above ground surface																	
10. Pump Test																	
Pumping level 30 ft. below surface																	
Pumping at 50 GP M for 1 Hrs.																	
Pumping Method ? Airlift																	
11. Well Is																	
24 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ? No																	
Filled & Sealed Well(s) as needed? No																	
13. Constructor / Supervisory Driller				Lic #		Date Signed											
JDD				6331		03-20-2026											
Drill Rig Operator				Lic or Reg #		Date Signed											
JL				7417		03-20-2026											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		20

Comment:

Created On: 12-15-2025

Updated On: 04-13-2026

Review Status: APPROVED