

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK889		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BOYEAU, GREG					Phone # (920)609-7942		1. Well Location				Fire # (if avail.)						
Mailing Address 2640 FREEDOM RD					Town of GOODMAN					W6293							
City DEPERE					State WI		Zip Code 54115					Street Address or Road Name and Number W6293 NORTH LOOP DRIVE					
County Marinette		Co. Permit #		Notification # 9987127401		Completed 10-29-2025		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) MORIN, DOUGLAS J				Lic. # 6311		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.71009 °N -88.41382 °W			Method Code GPS008						
Address MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151				Well Plan Approval #		SW SE		Section 6		Township 37 N		Range 17 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #			Common Well #		Specific Capacity 1		2. Well Type Replacement										
							of previous unique well # constructed in										
Reason for replaced or reconstructed well ? UPDATE FROM POINT WELL																	
3. Well serves 1 # of COTTAGE			Hicap Well ? No				Construction Type Drilled										
Private, potable Drillhole			Hicap Property ? No														
Heat Exchange ____ # of drillholes			Hicap Potable ? No														
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		50						T Q S S		T-TAN/BROWN Q-CAVING S-SAND S-SANDY		Surface		15	
						No Rotary - Mud Circulation		No		T V G Z		T-TAN/BROWN V-NON-CAVING G-GRAVEL/STONES Z-W/COBBLES/BOULDERS		15		32	
						No Rotary - Air		No		T H Z C		T-TAN/BROWN H-HARD/FIRM Z-CLAY & GRAVEL C-CLAYEY		32		45	
						No Rotary - Air & Foam		No		T Q S S		T-TAN/BROWN Q-CAVING S-SAND S-SANDY		45		50	
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ____ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ____ in. dia											
						No Removed? ____ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		5 ft. below ground surface				11. Well Is			
6		ASTM A53B 18.97 LB/FT WELDED NUCOR				Surface		50		10. Pump Test				24 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Developed ? Yes			
										Pumping at 15 GP M for 4 Hrs.				Disinfected ? Yes			
										Pumping Method ? Test Pump				Capped ? Yes			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes					
Method		MOUNDED										Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE		Surface		50		2 S											
13. Constructor / Supervisory Driller												Lic #		Date Signed			
DJM												6311		12-15-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			
DJM												6311		12-15-2025			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	150	POWTS holding component (also known as holding tank)	>	65

Comment:

Created On: 12-15-2025

Updated On: 01-21-2026

Review Status: APPROVED