# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACK889

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: BOYEAU, GREG | Phone #: (920)609-7942 |
| Mailing Address: 2640 FREEDOM RD | |
| City: DEPERE | State: WI — Zip Code: 54115 |
| County: Marinette | Co. Permit #: — Notification #: 9987127401 — Completed: 10-29-2025 |
| Well Constructor (Business Name): MORIN, DOUGLAS J | Lic. #: 6311 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy): |
| Address: MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151 | |
| Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1 | |

**1. Well Location**

| | |
|---|---|
| Town of GOODMAN | Fire # (if avail.): W6293 |
| Street Address or Road Name and Number: W6293 NORTH LOOP DRIVE | |
| Subdivision Name: — Lot #: — Block #: — | |
| Latitude / Longitude in Decimal Degree (DD): 45.71009 °N -88.41382 °W | Method Code: GPS008 |
| SW SE or Govt Lot #: — Section: 6 — Township: 37 N — Range: 17 E | |

**2. Well Type** Replacement

of previous unique well #: — constructed in: —

Reason for replaced or reconstructed well ?: UPDATE FROM POINT WELL

Construction Type: Drilled

**3. Well serves** 1 # of COTTAGE

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 50 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| T | Q | S | S | T-TAN/BROWN Q-CAVING S-SAND S-SANDY | Surface | 15 |
| T | V | G | Z | T-TAN/BROWN V-NON-CAVING G-GRAVEL/STONES Z-W/COBBLES/BOULDERS | 15 | 32 |
| T | H | Z | C | T-TAN/BROWN H-HARD/FIRM Z-CLAY & GRAVEL C-CLAYEY | 32 | 45 |
| T | Q | S | S | T-TAN/BROWN Q-CAVING S-SAND S-SANDY | 45 | 50 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | ASTM A53B 18.97 LB/FT WELDED NUCOR | Surface | 50 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | 50 | 2 S |

**9. Static Water Level**

5 ft. below ground surface

**10. Pump Test**

Pumping level 20 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ? Test Pump

**11. Well Is**

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

| 13. Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| DJM | 6311 | 12-15-2025 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| DJM | 6311 | 12-15-2025 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| Lake, Stream, River or Pond (Including Storm Water Detention Basin) | > | 150 | POWTS holding component (also known as holding tank) | > | 65 |

Comment:

Created On: 12-15-2025 Updated On: 01-21-2026 Review Status: APPROVED