

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACK908		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DUNNIGAN, JOSEPH						Phone # (612)419-8966		1. Well Location				Fire # (if avail.)					
Mailing Address 2258 99TH ST						Town of GEORGETOWN						2258					
City LUCK						State WI		Zip Code 54853				Street Address or Road Name and Number 99TH ST					
County Polk		Co. Permit #		Notification # 10073155701		Completed 11-21-2025		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) BEECROFT, BRANT C				Lic. # 7298		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.5358 °N -92.3618 °W				Method Code SCR002					
Address DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 9 35 N 16 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		Hicap Well ? No											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		140		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				C G C-CLAY G-W/GRAVEL/STONES Y Y-SAND & GRAVEL P Z P-HARDPAN Z-W/COBBLES/BOULDERS Z Z-CLAY & GRAVEL Y Y-SAND & GRAVEL Y C Y-SAND & GRAVEL C-CLAYEY Y Y-SAND & GRAVEL		Surface 7 7 37 37 78 78 90 90 93 93 130 130 140					
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 63 ft. below ground surface				11. Well Is 24 in. above grade			
5		MURIUCHI ASTM A53B PLN END BT WLD				Surface		136.8		10. Pump Test Pumping level 80 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		#12 JOHNSON SS				136.8		140									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE				Surface		136		2 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
BCB												7298		12-30-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	100	POWTS holding component (also known as holding tank)		45

Comment:

Created On: 12-16-2025

Updated On: 01-27-2026

Review Status: APPROVED