Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK908

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DUNNIGAN, JOSEPH	Phone #: (612)419-8966
Mailing Address: 2258 99TH ST	
City: LUCK	State: WI — Zip Code: 54853
County: Polk	Co. Permit #:
Notification #: 10073155701	Completed: 11-21-2025
Well Constructor (Business Name): BEECROFT, BRANT C	Lic. #: 7298
Facility ID # (Public Wells):	
Address: DANWELL COMPANY LLC 181 305TH AVE FREDERIC WI 54837	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.9	

1. Well Location

Town of GEORGETOWN	Fire # (if avail.): 2258
Street Address or Road Name and Number: 99TH ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.5358 °N -92.3618 °W	Method Code: SCR002
SW NW or Govt Lot #:	Section: 9 — Township: 35 N — Range: 16 W

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	7
		Y		Y-SAND & GRAVEL	7	37
		P	Z	P-HARDPAN Z-W/COBBLES/BOULDERS	37	78
		Z		Z-CLAY & GRAVEL	78	90
		Y		Y-SAND & GRAVEL	90	93
		Y	C	Y-SAND & GRAVEL C-CLAYEY	93	130
		Y		Y-SAND & GRAVEL	130	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	MURIUCHI ASTM A53B PLN END BT WLD	Surface	136.8
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	#12 JOHNSON SS	136.8	140

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	136	2 S

9. Static Water Level
63 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BCB	7298	12-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	100	POWTS holding component (also known as holding tank)		45

Comment:

Created On: 12-16-2025 Updated On: 01-27-2026 Review Status: APPROVED