Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACK954

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FENSKE, MITCHELL	Phone #
Mailing Address: N9110 YOUMG RD	
City: MINDORO	State: WI — Zip Code: 54644
County: La Crosse	Co. Permit #: 2025030 — Notification #: 10105278901 — Completed: 12-17-2025
Well Constructor (Business Name): LYSAKER, DAVID LLOYD	Lic. #: 8130 — Facility ID # (Public Wells):
Address: 11982 SOUTH ST, TREMPEALEAU WI 54661	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.9

1. Well Location

Town of FARMINGTON	Fire # (if avail.): N9110
Street Address or Road Name and Number: N9110 YOUMG RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0512 °N -91.0806 °W	Method Code: SCR002
SW NE or Govt Lot #:	Section: 10 — Township: 18 N — Range: 6 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	25
T	S	X		T-TAN/BROWN S-SOFT/LOOSE X-SAND & CLAY	25	33
G	M	H		G-GRAY M-MEDIUM H-SHALE	33	44
G	M	N	H	G-GRAY M-MEDIUM N-SANDSTONE H-SHALEY	44	55
G	H	N	H	G-GRAY H-HARD/FIRM N-SANDSTONE H-SHALEY	55	75
G	H	N		G-GRAY H-HARD/FIRM N-SANDSTONE	75	95
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	95	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO NEW P.E. BLACK STEEL ASTM A 53 B 18.97# .280 WALL	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	57	2.5 S

9. Static Water Level	11. Well Is	
30 ft. below ground surface	18 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 50 ft. below surface	Disinfected ?	Yes
Pumping at 18 GP M for 12 Hrs.	Capped ?	Yes
Pumping Method ? Test Pump		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DL	8130	12-17-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		30
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Drain - Sanitary		25
Sewer - Building Sanitary		20

Comment:

Created On: 12-17-2025 Updated On: 10-15-2026 Review Status: APPROVED