Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL024

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BODSBERG, MIKE	Phone #
Mailing Address: E2453 1070TH AVE	
City: BOYCEVILLE	State: WI — Zip Code: 54725
County: Dunn	Co. Permit #: 2507293 — Notification #: 9954112901 — Completed: 12-01-2025
Well Constructor (Business Name): DAHL WELL DRILLING LLC	Lic. #: 6724 — Facility ID # (Public Wells)
Address: 1236 HAGAN RD, GLENWOOD CITY WI 54013	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.9

1. Well Location

Town of TIFFANY	Fire # (if avail.): E2453
Street Address or Road Name and Number: 1070TH AVE	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 45.069 °N -92.037 °W	Method Code: GPS008
SE NE or Govt Lot #	Section: 23 — Township: 30 N — Range: 14 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	64

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	I		T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	1
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	1	44
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	44	64

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARVICHI LEAVIT, STEEL, WELDED, 20#/FT, .280 WALL	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	JOHNSON, SST, .010 SLOT	60	64

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	60	7 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AD	6830	02-26-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		30	POWTS dispersal component (soil absorption unit or mound)		55

Comment:

Created On: 12-22-2025 Updated On: 03-24-2026 Review Status: APPROVED