Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL066

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRAUSE, ED	Phone #: (414)573-1129
Mailing Address: 4701 103RD ST	
City: PLEASANT PRAIRIE	State: WI — Zip Code: 53158
County: Florence	Co. Permit #:
Notification #: 10003620501	Completed: 11-11-2025

1. Well Location

Fire # (if avail.): 1535

Town of HOMESTEAD

Street Address or Road Name and Number: 1535 SCOUT LAKE RD

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): MORIN, DOUGLAS J	Lic. #: 6311
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4.3	

Latitude / Longitude in Decimal Degree (DD): 45.77918 °N -88.31054 °W

Method Code: GPS008

SW SE or Govt Lot #: | Section: 12 | Township: 38 N | Range: 17 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Drillhole

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	Surface	20
T	H	G	G	T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES G-W/GRAVEL/STONES	20	30
T	E	S	S	T-TAN/BROWN E-CLEAN S-SAND S-SANDY	30	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B 18.97 LB/FT WELDED NUCOR	Surface	39
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS TELESCOPING #12	39	46

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	39	2 S

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 24 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Other

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM	6311	12-23-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJM	6311	12-23-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)	>	58

Comment:

Created On: 12-23-2025 Updated On: 01-26-2026 Review Status: APPROVED