Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL068

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROLTGEN, GREG	Phone #: (262)894-7225
Mailing Address: 1070 MAYO RD	
City: HARTFORD	State: WI — Zip Code: 53027
County: Florence	Co. Permit #:
Notification #: 10013368701	Completed: 10-30-2025
Well Constructor (Business Name): MORIN, DOUGLAS J	Lic. #: 6311
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MORIN AND JOHNSON WELL DRLG & PUMP 670 COOLIDGE AVE NIAGARA WI 54151	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Town of HOMESTEAD	Fire # (if avail.): 5373
Street Address or Road Name and Number: 5373 WOLFFE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.78124 °N -88.33329 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 11 — Township: 38 N — Range: 17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	51

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	Surface	51

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B 18.97 LB/FT WELDED NUCOR	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS TELESCOPING #15	48	51

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	48	2 S

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 5 GP M for 2 Hrs.

Pumping Method ? Other

11. Well Is

20 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM	6311	12-23-2025
Drill Rig Operator	Lic or Reg #	Date Signed
DJM	6311	12-23-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	35	POWTS dispersal component (soil absorption unit or mound)	=	52

Comment:

Created On: 12-23-2025 Updated On: 01-26-2026 Review Status: APPROVED