Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL123

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SUMMIT DEVELOPEMENT GROUP			Phone #
Mailing Address: 770 ODSILA WAY			
City: FONTANA	State: WI	Zip Code: 53125	
County: Walworth	Co. Permit #:	Notification #: 10097975401	Completed: 12-23-2025

1. Well Location

Town of DELAVAN

Fire # (if avail.)

Street Address or Road Name and Number: 4227 CHESTNUT ST

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): BINZ, DAVID J	Lic. #: 5271	Facility ID # (Public Wells)	
Address: BINZ & SONS WELL & PUMP 2411 DUNHAM WOODS RD HARVARD IL 60033-9759		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1	

Latitude / Longitude in Decimal Degree (DD): 42.58552 °N -88.64523 °W | Method Code: GPS008

SW	SE	Section	Township	Range
or Govt Lot #		31	2 N	16 E

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?: LACK OF WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	91

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	C		K-BLACK S-SOFT/LOOSE C-CLAY	Surface	10
	N	Y		N-FINE Y-SAND & GRAVEL	10	20
R		C		R-RED C-CLAY	20	28
		X		X-SAND & CLAY	28	36
R		S		R-RED S-SAND	36	48
R		Z		R-RED Z-CLAY & GRAVEL	48	55
	N	Y		N-FINE Y-SAND & GRAVEL	55	91

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC GLUE	Surface	82
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	20 SLOT STAINLESS	82	91

9. Static Water Level

1 ft. above ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 5 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO GRANULAR GROUT	Surface	80	8 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

OLD WELL WAS ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJB	5271	12-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: WELL YIELD 5 GPM

Created On: 12-30-2025 Updated On: 01-22-2026 Review Status: APPROVED