

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL123		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SUMMIT DEVELOPEMENT GROUP						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 770 ODSILA WAY						Town of DELAVAN															
City FONTANA						State WI		Zip Code 53125													
County Walworth		Co. Permit #		Notification # 10097975401		Completed 12-23-2025		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) BINZ, DAVID J				Lic. # 5271		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.58552 °N -88.64523 °W				Method Code GPS008							
Address BINZ & SONS WELL & PUMP 2411 DUNHAM WOODS RD HARVARD IL 60033-9759				Well Plan Approval #		SW SE		Section 31		Township 2 N		Range 16 E									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type Replacement											
3. Well serves 1 # of HOME				Hicap Well ? No		or Govt Lot #				of previous unique well #				constructed in							
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?				LACK OF WATER											
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		91		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						K S C		K-BLACK S-SOFT/LOOSE C-CLAY		Surface		10			
												N Y		N-FINE Y-SAND & GRAVEL		10		20			
												R C		R-RED C-CLAY		20		28			
												X		X-SAND & CLAY		28		36			
												R S		R-RED S-SAND		36		48			
												R Z		R-RED Z-CLAY & GRAVEL		48		55			
												N Y		N-FINE Y-SAND & GRAVEL		55		91			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		1 ft. above ground surface				24 in. above grade							
5		SDR17 PVC GLUE				Surface		82		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes							
5		20 SLOT STAINLESS				82		91		Pumping at 5 GP M for 3 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material										Pumping Method ? Test Pump											
Method TREMIE PIPE - PUMPED										12. Notified Owner of need to fill & seal ? No											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes											
CETCO GRANULAR GROUT				Surface		80		8 S		OLD WELL WAS ABANDON											
										13. Constructor / Supervisory Driller				Lic #		Date Signed					
										DJB				5271		12-30-2025					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: WELL YIELD 5 GPM

Created On: 12-30-2025

Updated On: 01-22-2026

Review Status: APPROVED