Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACL153

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	INGROULLIE, PATRICK AND MARY
Phone #	
Mailing Address	909 THISTLE LANE
City	EAU CLAIRE
State	WI
Zip Code	54703
County	Chippewa
Co. Permit #	20250211
Notification #	10058326401
Completed	03-26-2026
Well Constructor (Business Name)	MIDWEST WELL DRILLING & HYDROFRACKING LLC
Lic. #	6799
Facility ID # (Public Wells)	
Address	31569 150TH AV CORNELL WI 54732-6100
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.8

1. Well Location

Fire # (if avail.)	10016
Town of TILDEN	
Street Address or Road Name and Number	COUNTY HWY N
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.9461 °N -91.4663 °W
Method Code	GPS008
SW SW or Govt Lot #	
Section	34
Township	29 N
Range	9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	54
6	54	200

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	5
Y	H	N		Y-YELLOW H-HARD/FIRM N-SANDSTONE	5	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97#FT A53B HUSTEEL PE WELDED	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

133 ft. below ground surface

10. Pump Test

Pumping level 146 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	54	19 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		101

Comment:

Created On: 01-02-2026 Updated On: 10-15-2026 Review Status: APPROVED