Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL158

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: FOREST LODGE LIBRARY	Phone #
Mailing Address: 13450 COUNTY HWY M	
City: CABLE	State: WI Zip Code: 54821
County: Bayfield	Co. Permit #:	Notification #: 10055821601	Completed: 11-15-2025
Well Constructor (Business Name): ANDERSON, PAUL R	Lic. #: 4681	Facility ID # (Public Wells): 804087570
Address: PAUL R ANDERSON WELL DRILLING 60995 WIBERG RD ASHLAND WI 54806	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1

1. Well Location

Town of CABLE	Fire # (if avail.): 13450
Street Address or Road Name and Number: COUNTY HWY M	
Subdivision Name:	Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 46.20792 °N -91.29189 °W	Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		18	43 N	7 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of LIBRARY
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	6
4	6	91

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	G	G	T-TAN/BROWN V-NON-CAVING G-GRAVEL/STONES G-W/GRAVEL/STONES	Surface	50
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	50	88
T	W	S	S	T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY	88	91

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	4"ID T&D ASTM A-53-B WEATLAND	Surface	88
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	10 SLOT SCREEN 4X2 KPACK	88	91

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	6	4 S

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
PA	4681	01-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed
BH	7739	01-05-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Variance ID	Variance or Exception Type	Date	Reason
75294	Landfill Variance	07/15/2025	

Created On: 01-05-2026 Updated On: 10-19-2026 Review Status: APPROVED