

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL169		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BRYCE ANDERSON						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W1314 BEACH RD						Town of EAST TROY											
City EAST TROY						State WI		Zip Code 53120				Street Address or Road Name and Number W1314 BEACH RD					
County Walworth		Co. Permit #		Notification # 10121090301		Completed 12-20-2025		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) BIRSACK, ROBERT K				Lic. # 6413		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.8271 °N -88.3661 °W				Method Code SCR002					
Address BIRSACK WELL SERVICE W4502 ST RD 20 EAST TROY WI 53120				Well Plan Approval #		NE NE		Section 9		Township 4 N		Range 18 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5		2. Well Type Replacement						of previous unique well #		constructed in			
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ? POINT FAILED									
Private, potable						Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		38		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				Y Y Y G C G S		Y-YELLOW Y-SAND & GRAVEL G-GRAY C-CLAY G-GRAY S-SAND		Surface 21 30 30		21 30 38	
6. Casing, Liner, Screen														9. Static Water Level		11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		7 ft. below ground surface		14 in. above grade					
6		NOVA STEEL ASTM A53B 18.97 PPF P/E				Surface		35		10. Pump Test Pumping level 9 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Other		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		20 SLOT STAINLESS STEEL				35		38									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?		Yes	
Method MOUNDED														SEALED OLD WELL			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes			
GRANULAR BENTONITE				Surface						SEALED OLD WELL							
13. Constructor / Supervisory Driller														Lic #		Date Signed	
RB														6413		01-05-2026	
Drill Rig Operator														Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	50

Comment:

Created On: 01-05-2026

Updated On: 01-28-2026

Review Status: APPROVED