Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL184

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT LECIEJEWSKI	Phone #: (812)303-2929
Mailing Address: 3524 E SCHMITT LANE	
City: EVANSVILLE	State: IN — Zip Code: 47711
County: Bayfield	Co. Permit #:
Notification #: 10086953801	Completed: 12-15-2025
Well Constructor (Business Name): ANDERSON, PAUL R	Lic. #: 4681
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PAUL R ANDERSON WELL DRILLING 60995 WIBERG RD ASHLAND WI 54806	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

City of ASHLAND	Fire # (if avail.): 29730
Street Address or Road Name and Number: WOODLAND RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.5172 °N -90.9553 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 26 — Township: 47 N — Range: 5 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NOT ENOUGH WATER IN OLD WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	6
4	6	100

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	V	C	C	R-RED V-NON-CAVING C-CLAY C-CLAYEY	Surface	20
R	Q	C	C	R-RED Q-CAVING C-CLAY C-CLAYEY	20	97
T	W	S	S	T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY	97	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	OD 4 INCH ID T&C ASTM A-53-B WEATLAND	Surface	97
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	10 SLOT SCREEN 4X2 KPACK	97	100

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	6	6 S

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

NOT ENOUGH WATER

13. Constructor / Supervisory Driller	Lic #	Date Signed
PA	4681	01-06-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BH	7739	01-06-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25

Comment:

Created On: 01-06-2026 Updated On: 10-15-2026 Review Status: APPROVED