

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL196		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner FREI STEVEN					Phone #		1. Well Location Fire # (if avail.) Town of DAYTON N1391 Street Address or Road Name and Number MCALLISTER RD				Subdivision Name Lot # Block #		
Mailing Address N1391 MCALLISTER ROAD													
City WAUPACA			State WI		Zip Code 54981								
County Waupaca		Co. Permit #		Notification # 10120667101		Completed 12-18-2025							
Well Constructor (Business Name) LOEHRKE, NEAL D				Lic. # 133		Facility ID # (Public Wells) Well Plan Approval #		Latitude / Longitude in Decimal Degree (DD)				Method Code	
								44.2886 °N -89.10999 °W				GPS008	
Address VALLEY WELL DRILLING N1600 HWY 10 S WEYAUWEGA WI 54983				Approval Date (mm-dd-yyyy)				SW SE Section Township Range					
								or Govt Lot # 2 13 21 N 11 E					
Hicap Permanent Well #			Common Well #		Specific Capacity 7		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? LOW CAPACITY Construction Type Drilled						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...			
6		Surface		64		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Y Y-SAND & GRAVEL Surface 42 S S-SAND 42 64			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 22 ft. below ground surface			
6		STEEL 18.97 LBS/FT A53B NUCOR WELDED				Surface		60		11. Well Is 20 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 24 ft. below surface Pumping at 14 GP M for 24 Hrs. Pumping Method ? Test Pump			
6		TELE SS 15 CSLOT				60		64		Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes			
GRANULAR BENTONITE				Surface				1 S		Filled & Sealed Well(s) as needed? Yes VALLEY WELL FILLED/SEALED 1.25 POINT			
								13. Constructor / Supervisory Driller Lic # Date Signed					
								NDL 133 12-18-2025					
								Drill Rig Operator Lic or Reg # Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-06-2026

Updated On: 02-03-2026

Review Status: APPROVED