Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL196

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FREI STEVEN	Phone #
Mailing Address: N1391 MCALLISTER ROAD	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: 10120667101 — Completed: 12-18-2025
Well Constructor (Business Name): LOEHRKE, NEAL D	Lic. #: 133 — Facility ID # (Public Wells):
Address: VALLEY WELL DRILLING N1600 HWY 10 S WEYAUWEGA WI 54983	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7

1. Well Location

Town of DAYTON	Fire # (if avail.): N1391
Street Address or Road Name and Number: MCALLISTER RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.2886 °N -89.10999 °W	Method Code: GPS008

SW	SE	Section	Township	Range
or Govt Lot # 2	13	21 N	11 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: LOW CAPACITY

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	64

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	42
		S		S-SAND	42	64

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LBS/FT A53B NUCOR WELDED	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELE SS 15 CSLOT	60	64

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 24 ft. below surface

Pumping at 14 GP M for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

VALLEY WELL FILLED/SEALED 1.25 POINT

13. Constructor / Supervisory Driller	Lic #	Date Signed
NDL	133	12-18-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-06-2026 Updated On: 02-03-2026 Review Status: APPROVED