

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL215		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner RITTER, CLAIRE				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 4108 SHERIDAN AVE. SOUTH						Village of WALWORTH					
City MINNEAPOIS				State MN		Zip Code 55410					
County Walworth		Co. Permit #		Notification # 10039419601		Completed 01-06-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) BINZ, DAVID J				Lic. # 5271		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.49888 °N -88.63907 °W		Method Code SCR002	
Address BINZ & SONS WELL & PUMP 2411 DUNHAM WOODS RD HARVARD IL 60033-9759				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 31 1 N 16 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4		2. Well Type Replacement of previous unique well # constructed in			
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ? LACK OF WATER Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
9		Surface		45		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)			
R C			R-RED C-CLAY			Surface		5			
Y			Y-SAND & GRAVEL			5		45			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
5		SDR 17 GLUE PVC				Surface		41			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
5		STAINLESS 20 SLOT				41		45			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
CETCO GRANULAR GROUT 20%				Surface		35		4 S			
9. Static Water Level											
6 ft. below ground surface											
10. Pump Test											
Pumping level 20 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ? Test Pump											
11. Well Is											
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #				Date Signed							
DJB				5271				01-07-2026			
Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-07-2026

Updated On: 01-29-2026

Review Status: APPROVED