Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL215

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RITTER, CLAIRE	Phone #
Mailing Address: 4108 SHERIDAN AVE. SOUTH	
City: MINNEAPOIS	State: MN Zip Code: 55410
County: Walworth	Co. Permit #:
Notification #: 10039419601	Completed: 01-06-2026
Well Constructor (Business Name): BINZ, DAVID J	Lic. #: 5271
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: BINZ & SONS WELL & PUMP 2411 DUNHAM WOODS RD HARVARD IL 60033-9759	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.4	

1. Well Location

Village of WALWORTH

Fire # (if avail.):

Street Address or Road Name and Number: 203 PRAIRIE VIEW RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 42.49888 °N -88.63907 °W

Method Code: SCR002

NE SE or Govt Lot #: | Section: 31 | Township: 1 N | Range: 16 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: LACK OF WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	45

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	5
		Y		Y-SAND & GRAVEL	5	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR 17 GLUE PVC	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS 20 SLOT	41	45

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO GRANULAR GROUT 20%	Surface	35	4 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJB	5271	01-07-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-07-2026 Updated On: 01-29-2026 Review Status: APPROVED