

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL235		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BORNTRERGER, MELVIN						Phone #									
Mailing Address 406 310TH ST						1. Well Location						Fire # (if avail.)			
City WILSON						State WI		Zip Code 54027				Town of SPRINGFIELD		406	
Street Address or Road Name and Number						310H ST									
County St. Croix		Co. Permit #		Notification # 9991957201		Completed 09-16-2025		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) DAHL WELL DRILLING LLC				Lic. # 6724		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9501 °N -92.1774 °W				Method Code GPS008	
Address 1236 HAGAN RD GLENWOOD CITY WI 54013				Well Plan Approval #				NE SE		Section 34		Township 29 N		Range 15 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				2. Well Type New Well					
3. Well serves 1 # of HOME						Hicap Well ? No				of previous unique well # constructed in					
Private, potable Drillhole						Hicap Property ? No				Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes						Hicap Potable ? No				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		143		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam Yes No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
T	S	I						T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC	Surface		1				
T	Q	S	G					T-TAN/BROWN Q-CAVING S-SAND G-W/GRAVEL/STONES	1		4				
T	Q	S						T-TAN/BROWN Q-CAVING S-SAND	4		23				
O	Q	S						O-ORANGE Q-CAVING S-SAND	23		44				
T	S	N						T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE	44		52				
T	H	L						T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	52		84				
T	H	N						T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	84		130				
I	H	N						I-WHITE H-HARD/FIRM N-SANDSTONE	130		143				
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		MARVICH LEAVIT, STEEL, WELDED, 20# FT, .280 WALL				Surface		53							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		53		5 S							

9. Static Water Level

51 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

AD

6830

02-26-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Created On: 01-09-2026

Updated On: 03-24-2026

Review Status: APPROVED