Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL269

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CHAMOUN, TUFFY	Phone #
Mailing Address: 465 NERRY OAKS DR	
City: SYCAMORE	State: IL — Zip Code: 60178
County: Juneau	Co. Permit #: — Notification #: 10129139401 — Completed: 01-12-2026
Well Constructor (Business Name): NELSONS PLBG & ELEC INC	Lic. #: 42 — Facility ID # (Public Wells):
Address: 25269 HWY 12, TOMAH WI 54660-5174	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of GERMANTOWN	Fire # (if avail.): N8453
Street Address or Road Name and Number: TIMBER TRAIL	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.95 °N -90.0654 °W	Method Code: GPS008
NW NE or Govt Lot #:	Section: 18 — Township: 17 N — Range: 4 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: SYSTEM UPGRADE
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	23
		Y		Y-SAND & GRAVEL	23	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND, STEEL PE WELD 18.97LB A#53	Surface	39
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS 10 SLOT JOHNSON	39	42

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 GRANULAR BENTONITE	Surface	1	5 S

9. Static Water Level
6 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? No
WILL BE DONE WHEN NEW IS ON LINE BY PLUMBER

13. Constructor / Supervisory Driller	Lic #	Date Signed
MN	3799	01-19-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CS	8031	01-19-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75

Type	Qualifier	Distance
Sewer - Building Sanitary	>	25
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 01-12-2026 Updated On: 02-09-2026 Review Status: APPROVED