

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL269		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CHAMOUN, TUFFY						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 465 NERRY OAKS DR						Town of GERMANTOWN						N8453									
City SYCAMORE						State IL		Zip Code 60178				Street Address or Road Name and Number									
County Juneau						Co. Permit #		Notification # 10129139401		Completed 01-12-2026		Subdivision Name		Lot #		Block #					
Well Constructor (Business Name) NELSONS PLBG & ELEC INC						Lic. # 42		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.95 °N -90.0654 °W				Method Code GPS008							
Address 25269 HWY 12 TOMAH WI 54660-5174						Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE		Section 18		Township 17 N		Range 4 E					
										or Govt Lot #											
Hicap Permanent Well #						Common Well #		Specific Capacity 0.6		2. Well Type Replacement											
Reason for replaced or reconstructed well ?						SYSTEM UPGRADE															
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled													
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
6		Surface		42		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen						8. Geology															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		WHEATLAND, STEEL PE WELD 18.97LB A#53				Surface		39		S		S-SAND		Surface		23					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Y		Y-SAND & GRAVEL		23		42					
6		SS 10 SLOT JOHNSON				39		42													
7. Grout or Other Sealing Material														9. Static Water Level				11. Well Is			
Method MOUNDED														6 ft. below ground surface				18 in. above grade			
Kind of Sealing Material						From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes							
#8 GRANULAR BENTONITE						Surface		1		Pumping level 30 ft. below surface				Disinfected ? Yes							
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Airlift											
						12. Notified Owner of need to fill & seal ? Yes															
						Filled & Sealed Well(s) as needed? No															
						WILL BE DONE WHEN NEW IS ON LINE BY PLUMBER															
						13. Constructor / Supervisory Driller				Lic #		Date Signed									
						MN				3799		01-19-2026									
						Drill Rig Operator				Lic or Reg #		Date Signed									
						CS				8031		01-19-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Sewer - Building Sanitary	>	25
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 01-12-2026

Updated On: 02-09-2026

Review Status: APPROVED