Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL270

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: G & G HOMESTEAD PROPERTIES			Phone #
Mailing Address: N3705 CTY RD G			
City: MAUSTON	State: WI	Zip Code: 54948	
County: Juneau	Co. Permit #:	Notification #: 10129983201	Completed: 02-05-2026

Well Constructor (Business Name): NELSONS PLBG & ELEC INC	Lic. #: 42	Facility ID # (Public Wells):	
Address: 25269 HWY 12 TOMAH WI 54660-5174		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of LINDINA				Fire # (if avail.): N3705
Street Address or Road Name and Number: CTY RD G				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7751 °N -90.0938 °W				Method Code: GPS008
SE SE or Govt Lot #	Section: 14	Township: 15 N	Range: 3 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
SYSTEM UPGRADE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	26
9.25	26	58
6	58	99

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
No	Removed? 26depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F		F-FILL	Surface	1
		S	C	S-SAND C-CLAYEY	1	6
T		C		T-TAN/BROWN C-CLAY	6	15
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	15	21
		Y	C	Y-SAND & GRAVEL C-CLAYEY	21	26
	S	N		S-SOFT/LOOSE N-SANDSTONE	26	28
	H	N		H-HARD/FIRM N-SANDSTONE	28	34
T	F	N		T-TAN/BROWN F-FRACTURED N-SANDSTONE	34	49
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	49	64
O		N		O-ORANGE N-SANDSTONE	64	87
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	87	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND, STEEL PE WELD 18.97LB A#53	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	58	22 S

9. Static Water Level	11. Well Is
13 ft. below ground surface	15 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 85 ft. below surface	Disinfected ? Yes
Pumping at 20 GP M for 2 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

PLUMBER TO DO WHEN NEW ON LINE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MN	3799	02-06-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CS	8031	02-06-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	>	1200

Comment:

Created On: 01-12-2026 Updated On: 02-24-2026 Review Status: APPROVED

WISCONSIN UNIQUE WELL NUMBER **ACL270**