Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL291

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: IKE BANASZAK	Phone #: (715)927-8020
Mailing Address: N4905 HWY 141	
City: BEAVER	State: WI — Zip Code: 54114
County: Marinette	Co. Permit #:
Notification #: 10128286401	Completed: 01-09-2026
Well Constructor (Business Name): COOPER, GERALD L	Lic. #: 6211
Facility ID # (Public Wells):	
Address: 5050 BROWN RD, LITTLE SUAMICO WI 54141	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.2	

1. Well Location

Town of STEPHENSON	Fire # (if avail.): N7146
Street Address or Road Name and Number: KIRBY LAKE LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.2202 °N -88.1088 °W	Method Code: SCR002

SE	NE	Section	Township	Range
or Govt Lot #		27	32 N	19 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
POINT NOT MAKING MUCH WATER

Construction Type: Drilled

3. Well serves 2 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	3
6	3	56

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	15
T	S	C	S	T-TAN/BROWN S-SOFT/LOOSE C-CLAY S-SANDY	15	35
T	H	G	S	T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES S-SANDY	35	44
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	44	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97 LB PER FT ASTM A53 NTP-TRI WELDED	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 18 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	44	1 S

12. Notified Owner of need to fill & seal ? Yes
WILL DO

Filled & Sealed Well(s) as needed? Yes
WILL DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
GLC	6211	01-13-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	50	POWTS dispersal component (soil absorption unit or mound)	>	50
			Building Drain - Sanitary	>	25

Comment:

Created On: 01-13-2026 Updated On: 10-15-2026 Review Status: APPROVED